

2021 Annual Drinking Water Quality Report

Laton Community Services District

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2021 and may include earlier monitoring data.

**Este informe contiene información muy importante sobre su agua de beber.
Tradúzcalo ó hable con alguien que lo entienda bien.**

We are pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide you with a safe and dependable supply of drinking water. Our water source comes from three active wells, Well No. 4, Well No. 5 and Well No. 6.

A source water assessment was conducted for the water supply wells of the Laton Community Services water supply wells in July, 2001. The sources are considered most vulnerable to the following activities not associated with any detected contaminants: sewer collection systems, historic gas stations and agricultural/irrigation wells. A copy of the complete assessment may be viewed at Laton Community Services District Office, 20798 S. Fowler Avenue, Laton CA. You may request a summary of the assessment be sent to you by contacting Mr. Daniel Chapa, General Manager, (559) 923-4802.

If you have any questions about this report or concerning your water utility, please contact Mr. Daniel Chapa, General Manager at (559) 923-4802. You may also write to Mr. Chapa at Laton Community Services District, P. O. Box 447, Laton, CA 93242. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Wednesday of every month at 6:00 p.m. at 6501 E. Latonia Street, Laton, CA.

The following are definitions of some of the TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs, MRDLs and treatment techniques (TT) for contaminants that affect health along with their monitoring and reporting requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

N/A: Not applicable

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

In general, sources of drinking water (both tap water and bottled water) may include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Constituents that may be present in source water to contamination levels include:

- Microbial contaminants such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.
- Radioactive contaminants that can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U. S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board – Division of Drinking Water (DDW) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. DDW regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Laton Community Service District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The following tables list all the drinking water constituents that were detected during the most recent samplings for the constituent. The presence of these constituents in the water does not necessarily indicate that the water poses a health risk. The DDW requires us to monitor for certain constituents less than once per year because the concentrations of these constituents are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are therefore more than one year old.

| SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA | | | | | |
|---|---------------------------|----------------------------|----------------------------------|------|--------------------------------------|
| Microbiological Contaminants | Highest No. of detections | No. of months in violation | MCL | MCLG | Typical Source of Contamination |
| E. coli (Revised Total Coliform Rule) | (In the year) 0 | 0 | (a) | 0 | Human and animal fecal waste |
| Total Coliform Bacteria | (In a month) 1 | 0 (b) | 1 positive monthly sample (b) | 0 | Naturally present in the environment |
| Fecal Coliform and E. coli | (In the year) 0 | 0 (c) | (c) | None | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E.coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli.

(b) In 2021, the Total Coliform Bacteria standard changed. Between January 1, 2021 and June 30, 2021, two or more positive monthly samples represents a violation of the MCL. Beginning July 1, 2021, two or more positive monthly samples triggers a TT assessment.

(c) Beginning July 1, 2021, the Revised Total Coliform Rule became effective. Between January 1, 2021 and June 30, 2021, the MCL criteria listed in Note (a) was enforced for Fecal Coliform and E. coli.

E. Coli/Fecal Coliform: E. coli/Fecal coliforms are bacteria whose presence indicate that water may be contaminated with human or animal wastes.

Total Coliform: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.

The District collects 5 samples each month.

| TEST RESULTS (A) | | | | | | | |
|----------------------|--------------------------|------|--------------|--|----------------------------------|--|---|
| Lead and Copper Rule | No. of samples collected | MCLG | Action Level | 90 th percentile level detected | No. Sites Exceeding Action Level | Number of Schools Requesting Lead Sampling | Typical Source of Contamination |
| Lead (ppb) 2021 | 10 | 2 | 15 | ND | 0 | 3 (Completed - 2018) | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) 2021 | 10 | 0.3 | 1.3 | 0.078 | 0 | N/A | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

| SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | |
|---|------|------------|-------------|------------------------|-----------|---|
| Chemical or Constituent (and reporting units) | MCL | PHG [MCLG] | Sample Date | Average Level Detected | Range | Typical Source of Contamination |
| Hardness (ppm) | None | None | 2020/2021 | 84 | 29 to 160 | Generally found in ground and surface water |
| Sodium (ppm) | None | None | 2020/2021 | 16 | 9.9 to 20 | Generally found in ground and surface water |

| DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|--|-----|------------|----------------|------------------------|------------------------|--|
| Chemical or Constituent (and reporting units) | MCL | PHG [MCLG] | Sample Date | Average Level Detected | Range (B) | Typical Source of Contamination |
| Nitrate as N (ppm) | 10 | 10 | 2019/2020/2021 | 0.6 | ND to 1.1 (C) | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| RADIOACTIVE CONTAMINANTS | | | | | | |
| Chemical or Constituent (and reporting units) | MCL | PHG [MCLG] | Sample Date | Average Level Detected | Range (B) | Typical Source of Contamination |
| Gross Alpha Activity (pCi/L) | 15 | N/A | 2013/2014/2018 | 6.3 | ND to 17.10 (D) | Erosion of natural deposits |

| DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD (E) | | | | | |
|--|------|-------------|------------------------|--------------|---|
| Chemical or Constituent (and reporting units) | MCL | Sample Date | Average Level Detected | Range (B) | Typical Source of Contamination |
| Chloride (ppm) | 500 | 2020/2021 | 8.3 | 1.8 to 17 | Runoff/leaching from natural deposits; seawater influence |
| Iron (ppb) | 300 | 2020/2021 | 160 | ND to 280 | Leaching from natural deposits; industrial wastes. |
| Specific Conductance (µS/cm) | 1600 | 2020/2021 | 220 | 140 to 350 | Substances that form ions when in water; seawater influence |
| Sulfate (ppm) | 500 | 2020/2021 | 10.4 | 4.1 to 16 | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids (TDS) (ppm) | 1000 | 2020/2021 | 142 | 95 to 220 | Runoff/leaching from natural deposits |
| Turbidity (Units) | 5 | 2020/2021 | 0.39 | 0.24 to 0.61 | Soil runoff |

| DETECTION OF SYNTHETIC ORGANIC CONTAMINANTS INCLUDING PESTICIDES & HERBICIDES | | | | | | |
|---|-----|------------|-------------|------------------------|---------|--|
| Constituent | MCL | PHG [MCLG] | Sample Date | Average Level Detected | Range | Typical Source of Contamination |
| Trichloropropane (1,2,3-TCP) (ppt) | 5 | 0.7 | 2019/2021 | ND | N/A (F) | Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct of other compounds and pesticides. |

(A) Results reported due to regulatory requirement or detection of a constituent.

(B) Results reported include amounts that are less than the State Water Resources Control Board – Division of Drinking Water (DDW) required detection level for this contaminant.

(C) ABOUT NITRATE: Nitrate in drinking water at levels above 10 mg/L (as N) is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels as N that are above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

(D) ABOUT GROSS ALPHA ACTIVITY: Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

(E) ABOUT SECONDARY DRINKING WATER STANDARDS: Secondary MCLs are set to protect you against unpleasant aesthetic affects such as color, taste, odor or appearance of drinking water. The elevated levels are typically naturally occurring.

(F) ABOUT 1,2,3-TCP: Some people who drink water containing 1,2,3-trichloropropane (1,2,3-TCP) in excess of the MCL over many years may have an increased risk of getting cancer. 1,2,3-TCP had a notification level (NL) of 5 ppt until December 14, 2017, when the MCL of 5 ppt became effective.

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of constituents does not necessarily indicate that the water poses a health risk. More information about constituents, contaminant levels and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791 or their website <http://www.epa.gov/safewater/hfacts.html>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders and some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.